

IACS CIC for Emergency Power Supply Testing	
Date of Survey :	
Inspection Port :	
Kind of Ship Type :	
Kind of Survey :	
Date of Build:	

This inspection campaign will be held for 12 months commencing from 1 January 2025 and ending 31 December 2025 and examine the Emergency Power Supply of the ship. A ship will be subject to only one inspection under this CIC during the period of the IACS campaign.

	Items	Yes	No
Q1	Has a risk assessment or similar measures in the Safety Management System (SMS) for the emergency generator test?		
Q2	Has the controlled blackout test been successfully performed?		
Q3	If "No" is ticked in Q2, select the reason for the same (More than one options may be selected, if applicable).		
a.	Malfunction of control unit/circuit (i.e, Printed Circuit Boards or control relay unit, etc.)		
b.	Malfunctioned Air Circuit Breaker		
c.	Miss-selection of engine starting selection switch mode in emergency generator room		
d.	Closing Quick-closing valve		
e.	Malfunction of starting arrangement		
f.	Malfunction of engine		
g.	No power supply to the services essential for safety in an emergency		
h.	Port restriction/regulation		
i*.	Others (please describe in the below note)		

Note: If “Yes” is selected for item "i" marked with an asterisk “*”, the reason may be described below.